

Doncaster District - Public Register of Notices Serviced – April 2008 to March 2009

Date on which notice served:	07/07/2008
Name of Organisation:	Milton Court, Milton Walk, Doncaster, DN1 3SS
Type of notice served:	Enforcement
Details:	<p>To take such general fire precautions as will ensure the safety of employees.</p> <p>To take such general fire precautions as will ensure the safety of persons who are not his employee.</p> <p>The escape routes did not lead, as directly as possible, to a place of safety.</p> <p>Insufficient evacuation procedures and/or evacuation drills to be followed in the event of serious and imminent danger are in place.</p> <p>Insufficient competent persons have been nominated to carry out evacuation procedures.</p> <p>The structural fire precautions are inadequately maintained.</p>
Reference No	EN.D.02.08
Date of compliance of notice:	04/08/2008

Date on which notice served:	24/07/2008
Name of Organisation:	The Frenchgate Centre, St Sepulchre Gate, Doncaster, DN1 1SZ
Type of notice served:	Enforcement
Details:	<p>To take such general fire precautions as will ensure the safety of employees.</p> <p>To take such general fire precautions as will ensure the safety of persons who are not his employees.</p> <p>A Fire Safety Risk Assessment was not available at the time of the inspection.</p> <p>The Fire Safety Risk Assessment has not taken into account a significant change.</p> <p>The fire safety policy document was not suitable and sufficient.</p> <p>The escape routes and exists could not be used as quickly and as safely as possible.</p> <p>The fire alarm system is inadequately maintained.</p> <p>The emergency lighting is inadequately maintained.</p> <p>There were insufficient numbers of competent persons appointed to assist in undertaking preventive and protective measures.</p> <p>There were insufficient co-operations between competent persons appointed for the purposes of assisting with preventive and protective measures.</p> <p>There was inadequate time and means provided to enable a competent person appointed for the purposes of assisting with preventive and protective measures to fulfil their function.</p> <p>To provide comprehensible and relevant information to employees on preventive and protective measures.</p> <p>To provide comprehensible and relevant information to employees on appropriate procedures and drills to be followed in the event of serious and imminent danger.</p> <p>Inadequate safety training is provided to enable the employees to safeguard themselves and other persons on the premises.</p> <p>Inadequate co-ordination with other responsible persons sharing the same premises to comply with the requirements and prohibitions imposed under the Regulatory Reform (Fire Safety) Order 2005.</p>

Reference No	EN.D.04.08
Date of compliance of notice:	04/12/2008

Date on which notice served:	13/08/2008
Name of Organisation:	The New Masons Arms, Doncaster Road, Mexborough, S64 0JW
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees. Appropriate and evacuation drills to be followed in the event of serious and imminent danger are not in place. The emergency lighting is inadequately maintained. The fire retardant upholstery is inadequately maintained, resulting in exposure of flammable filling material. The manual fire fighting equipment is inadequately maintained.
Reference No	EN.D.05.08
Date of compliance of notice:	12/11/2008

Date on which notice served:	04/11/2008
Name of Organisation:	Tesco Filling Station, Woodfield Way, Balby, Doncaster, DN4 8SN
Type of notice served:	Enforcement
Details:	The Fire Safety Risk Assessment was not suitable and sufficient. The Fire Safety Risk Assessment did not include consideration of the risks posed by dangerous substances and is not in accordance with the measures specified in Part 1 of Schedule 1 of the Regulatory Reform (Fire Safety) Order 2005.
Reference No	EN.D.06.08
Date of compliance of notice:	28/11/2008

Date on which notice served:	18/02/2009
Name of Organisation:	Wyndthorpe Hall, High Street, Dunsville, Doncaster, DN7 4DB
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees. The Fire Safety Risk Assessment has not been reviewed on a regular basis. The fire detection system is inadequate. The escape routes and exits could not be used as quickly and as safely as possible. The structural fire precautions are inadequately maintained. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained. An employee failed to co-operate with his employer which would have enabled the employer to comply with a duty or requirement imposed under the Regulatory Reform (Fire Safety) Order 2005 so far as is necessary.
Reference No	EN.D.01.09
Date of compliance of notice:	30/04/2009

Date on which notice served:	24/02/2009
Name of Organisation:	Stoneacre, Barnby Dun Road, Doncaster, DN2 4QP
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees.

	<p>To take such general fire precautions as will ensure the safety of persons who are not his employees.</p> <p>A fire safety policy document has not been prepared.</p> <p>The escape routes were obstructed.</p> <p>The escape routes and exits could not be used as quickly and as safely as possible.</p> <p>Insufficient evacuation procedures and/or evacuation drills to be followed in the event of serious and imminent danger are in place.</p> <p>Insufficient competent persons have been nominated to carry out evacuation procedures.</p> <p>The measures taken for a person to be able to stop work and evacuate to a place of safety was inadequate.</p> <p>The structural fire precautions are inadequately maintained.</p> <p>The emergency lighting is inadequately maintained.</p> <p>There was insufficient co-operation between competent persons appointed for the purposes of assisting with preventive and protective measures.</p> <p>An employee failed to take reasonable care for the safety of himself and/or other relevant persons who were affected by his acts or omissions at work.</p>
Reference No	EN.D.02.09
Date of compliance of notice:	26/03/2009

Date on which notice served:	26/02/2009
Name of Organisation:	Tesco Filling Station, Woodfield Way, Balby, Doncaster, DN4 8SN
Type of notice served:	Enforcement
Details:	<p>To take such general fire precautions as will ensure the safety of employees.</p> <p>To take such general fire precautions as will ensure the safety of persons who are not his employee.</p> <p>The Fire Safety Risk Assessment was not suitable and sufficient.</p> <p>The Fire Safety Risk Assessment did not include consideration of the risks posed by dangerous substances and is not in accordance with the measures specified in Part 1 of Schedule 1 of the Regulatory Reform (Fire Safety) Order 2005.</p> <p>Inadequate safety training is provided to enable the employees to safeguard themselves and other persons on the premises.</p>
Reference No	EN.D.03.09
Date of compliance of notice:	31/03/2009

Date on which notice served:	26/02/2009
Name of Organisation:	Tesco Filling Station, Thorne Road, Edenthorpe, Doncaster, DN3 2JE
Type of notice served:	Enforcement
Details:	<p>To take such general fire precautions as will ensure the safety of employees.</p> <p>To take such general fire precautions as will ensure the safety of persons who are not his employees.</p> <p>The Fire Safety Risk Assessment was not suitable and sufficient.</p> <p>The Fire Safety Risk Assessment did not include consideration of the risks posed by dangerous substances and is not in accordance with the measures specified in Part 1 of Schedule 1 of the Regulatory Reform (Fire Safety) Order 2005.</p>
Reference No	EN.D.04.09
Date of compliance of notice:	31/03/2009

Date on which notice served:	26/02/2009
Name of Organisation:	Asda Filling Station, Herten Way, Doncaster, DN4 7NW
Type of notice served:	Enforcement
Details:	<p>To take such general fire precautions as will ensure the safety of employees.</p> <p>To take such general fire precautions as will ensure the safety of persons who are not his employees.</p> <p>The Fire Safety Risk Assessment was not suitable and sufficient.</p> <p>The Fire Safety Risk Assessment did not include consideration of the risks posed by dangerous substances and is not in accordance with the measures specified in Part 1 of Schedule 1 of the Regulatory Reform (Fire Safety) Order 2005.</p> <p>Inadequate safety training is provided to enable the employees to safeguard themselves and other persons on the premises.</p>
Reference No	EN.D.05.09
Date of compliance of notice:	31/03/2009

Date on which notice served:	04/03/2009
Name of Organisation:	Hotei Shushi, 65-67 Silver Street, Doncaster, DN1 1JL
Type of notice served:	Enforcement
Details:	<p>To take such general fire precautions as will ensure the safety of employees.</p> <p>The escape routes were obstructed.</p> <p>The escape routes and exits could not be used as quickly and as safely as possible.</p> <p>Insufficient evacuation procedures and/or evacuation drills to be followed in the event of serious and imminent danger are in place.</p> <p>Insufficient competent persons have been nominated to carry out evacuation procedures.</p> <p>The structural fire precautions are inadequately maintained.</p> <p>The fire alarm system is inadequately maintained.</p> <p>The emergency lighting is inadequately maintained.</p>
Reference No	EN.D.06.09
Date of compliance of notice:	Premises became unoccupied before expiry date.

Date on which notice served:	19/03/2009
Name of Organisation:	First Sport, Frenchgate Centre, 2 St Sepulchre Gate, Doncaster, DN1 1TA
Type of notice served:	Enforcement
Details:	<p>To take such general fire precautions as will ensure the safety of employees.</p> <p>To take such general fire precautions as will ensure the safety of persons who are not his employees.</p> <p>The escape routes were obstructed.</p> <p>Fire exits and doors on escape routes could not be easily and immediately opened from the inside.</p>
Reference No	EN.D.07.09
Date of compliance of notice:	17/04/2009