

Doncaster District - Public Register of Notices Serviced – April 2009 to March 2011

Date on which notice served:	04/02/2011
Name of Organisation:	Danum Hotel, High Street, Doncaster DN1 1DN
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees and persons who are not his employees. The Fire Safety Risk Assessment was not suitable and sufficient. The escape routes were obstructed. The escape routes and exits could not be used as quickly and as safely as possible. The escape routes were not adequately lit. The structural fire precautions are inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	EN.E.117
Date of compliance of notice:	20/04/2011

Date on which notice served:	17/08/2010
Name of Organisation:	Kiss, 65-67 Silver Street, Doncaster DM1 1JL
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees. The escape routes were obstructed. The escape routes and exits could not be used as quickly and as safely as possible. Insufficient evacuation procedures and/or evacuation drills to be followed in the event of serious and imminent danger are in place. Insufficient competent persons have been nominated to carry out evacuation procedures. The structural fire precautions are inadequately maintained. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	END.06.09
Date of compliance of notice:	21/03/2011

Date on which notice served:	20/05/2010
Name of Organisation:	Waverley Primary School, Douglas Road, Balby, Doncaster, DN4 0UB
Type of notice served:	Prohibition
Details:	Inadequate means for warning in case of fire and inadequate means of escape from first floor.
Reference No	PN.D.01.10/11
Date of compliance of notice:	26/08/2010

Date on which notice served:	18/05/2010
Name of Organisation:	Poundstretcher, Wheatley Hall Road, Doncaster, DN2 4DE
Type of notice served:	Enforcement
Details:	The escape routes were not adequately lit.
Reference No	EN.D.01.10/11
Date of compliance of notice:	18/06/2010

Date on which notice served:	21/01/2010
Name of Organisation:	Superdrug, Unit 94, Frenchgate Centre, Doncaster, DN1 1QD
Type of notice served:	Enforcement
Details:	The escape routes and exits could not be used as quickly and as safely as possible.
Reference No	EN.D.14.09/10
Date of compliance of notice:	15/02/2010

Date on which notice served:	22/12/2009
Name of Organisation:	Currys, York Road, Doncaster, DN5 8AS
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees. To take such general fire precautions as will ensure the safety of persons who are not his employees. A Fire Safety Risk Assessment has not been carried out. The escape routes were obstructed.
Reference No	EN.D.13.09/10
Date of compliance of notice:	27/01/2010

Date on which notice served:	22/12/2009
Name of Organisation:	PC World, Off Newcomen Road, York Road, Doncaster, DN5 8AS
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees. To take such general fire precautions as will ensure the safety of persons who are not his employees. A Fire Safety Risk Assessment has not been carried out. The escape routes were obstructed.
Reference No	EN.D.12.09/10
Date of compliance of notice:	25/01/2010

Date on which notice served:	18/12/2009
Name of Organisation:	Pound World, 11 & 12 The Colonnades, Doncaster, DN1 3EG
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees. To take such general fire precautions as will ensure the safety of persons who are not his employees. A Fire Safety Risk Assessment has not been carried out. The escape routes were obstructed.
Reference No	EN.D.11.09/10
Date of compliance of notice:	25/01/2010

Date on which notice served:	18/12/2009
Name of Organisation:	All Things Nice, 9 The Colonnades, Doncaster, DN1 3EG
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees. To take such general fire precautions as will ensure the safety of persons who are not his employees. A Fire Safety Risk Assessment has not been carried out. The escape routes were obstructed.
Reference No	EN.D.10.09/10
Date of compliance of notice:	25/01/2010

Date on which notice served:	18/12/2009
Name of Organisation:	Iceland Foods, Princes Street, Doncaster, DN1 3NJ
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees. To take such general fire precautions as will ensure the safety of persons who are not his employees. A Fire Safety Risk Assessment has not been carried out. The escape routes were obstructed.
Reference No	EN.D.09.09/10
Date of compliance of notice:	25/01/2010

Date on which notice served:	18/12/2009
Name of Organisation:	Jack Fullertons Frozen Food, The Colonnades, Doncaster, DN1 3EG
Type of notice served:	Enforcement
Details:	The fire warning system is inadequate. To take such general fire precautions as will ensure the safety of persons who are not his employees. A Fire Safety Risk Assessment has not been carried out. The escape routes were obstructed.
Reference No	EN.D.08.09/10
Date of compliance of notice:	25/01/2010

Date on which notice served:	09/10/2009
Name of Organisation:	Woodborough Hotel, 2 Belle Vue Avenue, Doncaster, DN4 5DX
Type of notice served:	Prohibition
Details:	Inadequate fire detection and alarm system on second floor. The fire detection system is inadequate. The fire warning system is inadequate.
Reference No	PN/02/09
Date of compliance of notice:	

Date on which notice served:	06/10/2009
Name of Organisation:	Horse & Jockey, 154 St Sepulchre Gate, Doncaster, DN1 3AQ
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment was not available at the time of the inspection. To take such general fire precautions as will ensure the safety of employees. To take such general fire precautions as will ensure the safety of persons who are not his employees.
Reference No	EN.D.04.09/10
Date of compliance of notice:	17/12/2009

Date on which notice served:	08/09/2009
Name of Organisation:	Woodborough Hotel, 2 Bell Vue Avenue, Doncaster, DN4 5DX
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of persons who are not his employees. The Fire Safety Risk Assessment was not suitable and sufficient. The fire detection system is inadequate. Fire exits and doors on escape routes could not be easily and immediately opened from the inside.
Reference No	EN.D.07.09/10
Date of compliance of notice:	09/10/2009

Date on which notice served:	01/09/2009
Name of Organisation:	Bar NY, 20 Market Place, Doncaster, DN1 1ND
Type of notice served:	Enforcement
Details:	<p>To take such general fire precautions as will ensure the safety of employees.</p> <p>To take such general fire precautions as will ensure the safety of persons who are not his employees.</p> <p>A Fire Safety Risk Assessment has not been carried out.</p> <p>The escape routes were obstructed.</p> <p>The escape routes did not lead, as directly as possible, to a place of safety.</p> <p>The escape routes and exits could not be used as quickly and as safely as possible.</p> <p>Fire exits and doors on escape routes could not be easily and immediately opened from the inside.</p> <p>The escape routes were not provided with adequate signage.</p> <p>The escape routes were not adequately lit.</p> <p>Insufficient evacuation procedures and/or evacuation drills to be followed in the event of serious and imminent danger are in place.</p> <p>The structural fire precautions are inadequately maintained.</p> <p>The fire alarm system is inadequately maintained.</p>
Reference No	EN.D.06.09/10
Date of compliance of notice:	29/09/2009

Date on which notice served:	28/08/2009
Name of Organisation:	Warehouse Outlet, 30 Printing Office Street, Doncaster, DN1 1TR
Type of notice served:	Enforcement
Details:	<p>A Fire Safety Risk Assessment was not available at the time of the inspection.</p> <p>The escape routes were obstructed.</p> <p>The escape routes and exits could not be used as quickly and as safely as possible.</p> <p>The manual fire fighting equipment is inadequately maintained.</p>
Reference No	EN.D.05.09/10
Date of compliance of notice:	02/12/2009

Date on which notice served:	03/08/2009
Name of Organisation:	White Hart Hotel, High Street, Askern, Doncaster, DN6 0AB
Type of notice served:	Enforcement
Details:	<p>A Fire Safety Risk Assessment has not been carried out.</p> <p>A Fire Safety Risk Assessment was not available at the time of the inspection.</p> <p>The fire detection system is inadequate.</p> <p>The fire fighting equipment is inadequate.</p>
Reference No	EN.D.03.09/10
Date of compliance of notice:	13/08/2009

Date on which notice served:	20/07/2009
Name of Organisation:	Edlington Parks Nursing Home, Headingley Way, Edlington, Doncaster, DN12 1SB
Type of notice served:	Enforcement
Details:	<p>To take such general fire precautions as will ensure the safety of employees.</p> <p>The Fire Safety Risk Assessment was not suitable and sufficient.</p> <p>The escape routes were obstructed.</p>

	The escape routes did not lead, as directly as possible, to a place of safety. The structural fire precautions are inadequately maintained.
Reference No	EN.D.02.09/10
Date of compliance of notice:	21/08/2009

Date on which notice served:	16/07/2009
Name of Organisation:	South Yorkshire Hotel, Swinton Road, Mexborough, S64 9JB
Type of notice served:	Prohibition
Details:	Unsatisfactory means of escape from the second floor accommodation. Absence of a means of giving warning in case of fire.
Reference No	PN/01/09
Date of compliance of notice:	03/08/2010

Date on which notice served:	15/07/2009
Name of Organisation:	Dower House Restaurant, Market Place, Bawtry, Doncaster
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment was not available at the time of the inspection
Reference No	EN.D.01.09/10
Date of compliance of notice:	26/11/2009

Date on which notice served:	15/07/2009
Name of Organisation:	Dower House Restaurant, Market Place, Bawtry, Doncaster
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment was not available at the time of the inspection
Reference No	EN.D.01.09/10
Date of compliance of notice:	26/11/2009