

Barnsley District - Public Register of Notices Served – April 2011 to March 2013

Date on which notice served:	18/02/2013
Name of Organisation:	Crest Supermarket, 31-35 Doncaster Road, Goldthorpe, Rotherham S63 9HG
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out. The escape routes and exits could not be used as quickly and as safely as possible. The manual fire fighting equipment is inadequately maintained. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained. Safety training to employees is not repeated periodically.
Reference No	EN.NA.291
Date of compliance of notice:	18/09/2013

Date on which notice served:	30/01/2013
Name of Organisation:	Jafran, 7b Park Street, Wombwell, Barnsley S73 3AS
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment was not available at the time of the inspection. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	EN.NA.288
Date of compliance of notice:	07/03/2013

Date on which notice served:	30/10/2012
Name of Organisation:	Domino's Pizza, 16c Station Road, Chapeltown, Sheffield S35 2XH
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out. The manual fire fighting equipment is inadequately maintained. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained. Safety training to employees is not repeated periodically.
Reference No	EN.NA.276
Date of compliance of notice:	15/01/2013

Date on which notice served:	25/09/2012
Name of Organisation:	White Bear, 11 Church Street, Barnsley S70 2AB
Type of notice served:	Enforcement
Details:	The Fire Safety Risk Assessment was not suitable and sufficient. The escape routes and exits could not be used as quickly and as safely as possible. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained. Safety training to employees is not repeated periodically.
Reference No	EN.NA.270
Date of compliance of notice:	22/10/2012

Date on which notice served:	09/08/2012
Name of Organisation:	Button Mill Inn, Park Road, Worsbrough, Barnsley S70 5LJ
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment had not been carried out. The structural fire precautions are inadequately maintained. The manual fire fighting equipment is inadequately maintained. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained. Inadequate safety training is provided to employees at the time when they are first employed.
Reference No	EN.NA.263
Date of compliance of notice:	04/12/2012

Date on which notice served:	09/07/2012
Name of Organisation:	Jafran, 7b Park Street, Wombwell, Barnsley S73 0AS
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment was not available at the time of the inspection. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	EN.NA.249
Date of compliance of notice:	30/01/2013

Date on which notice served:	05/07/2012
Name of Organisation:	Spice of India, 203 Pontefract Road, Barnsley, S71 1HS
Type of notice served:	Enforcement
Details:	A Fire Risk Assessment has not been carried out.
Reference No	EN.NA.246
Date of compliance of notice:	03/08/2012

Date on which notice served:	29/06/2012
Name of Organisation:	The Mount, 32 Pontefract Road, Barnsley S70 1TG
Type of notice served:	Enforcement
Details:	A Fire Risk Assessment has not been carried out. The emergency lighting is inadequately maintained.
Reference No	EN NA 247
Date of compliance of notice:	27/07/2012

Date on which notice served:	15/06/2012
Name of Organisation:	China Moon, 37 Peel Street, Barnsley S70 2RJ
Type of notice served:	Enforcement
Details:	The Fire Safety Risk Assessment was not suitable and sufficient.
Reference No	EN.NA.244
Date of compliance of notice:	01/08/2012

Date on which notice served:	08/06/2012
Name of Organisation:	Enforcement
Type of notice served:	Healthmade Ltd, Royal Court Care Home, 22 Rock Mount, Hoyland, Barnsley S74 9RP
Details:	The Fire Safety Risk Assessment was not suitable and sufficient. Preventative and protective measures have not been implemented in

	accordance with the principles of prevention as specified in Part 3 or Schedule 1 of the Regulatory Reform (Fire Safety) Order 2005.
Reference No	EN.NA.223
Date of compliance of notice:	26/06/2012

Date on which notice served:	17/05/2012
Name of Organisation:	Cross Inn, 7 Summer Lane, Royston, Barnsley S71 4SE
Type of notice served:	Enforcement
Details:	The Fire Safety Risk Assessment was not suitable and sufficient. The fire detection system is inadequate. The manual fire fighting equipment is inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	EN.NA.238
Date of compliance of notice:	27/07/2012

Date on which notice served:	10/05/2012
Name of Organisation:	Middlecliffe WMC, 2 Middlecliffe Lane, Little Houghton, Barnsley S72 0HX
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out. The fire detection system is inadequate. Safety training to employees is not repeated periodically.
Reference No	EN.NA.235
Date of compliance of notice:	21/09/2012

Date on which notice served:	10/05/2012
Name of Organisation:	Chilli Lodge, Knabbs Lane, Silkstone Common, Barnsley S75 4RD
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out. The manual fire fighting equipment is inadequately maintained. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	EN.NA.234
Date of compliance of notice:	23/08/2012

Date on which notice served:	10/05/2012
Name of Organisation:	The Thaal, 18 Doncaster Road, Darfield, Barnsley, S73 9HH
Type of notice served:	Enforcement
Details:	The Fire Safety Risk Assessment was not suitable and sufficient. The escape routes and exits could not be used as quickly and as safely as possible. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained. Safety training to employees is not repeated periodically.
Reference No	EN.NA.233
Date of compliance of notice:	08/08/2012

Date on which notice served:	04/05/2012
Name of Organisation:	The Singing Man, The Green, Shafton, Barnsley S72 8PQ
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out.

Reference No	EN.NA.228
Date of compliance of notice:	27/06/2012

Date on which notice served:	04/05/2012
Name of Organisation:	Royal Oak, 31 Manchester Road, Deepcar, Sheffield, S36 2QX
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of employees and those who are not their employees. A Fire Safety Risk Assessment has not been carried out. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	EN.NA.226
Date of compliance of notice:	16/08/2012

Date on which notice served:	13/04/2012
Name of Organisation:	The Firs, 186c Dodworth Road, Barnsley, S70 6PD
Type of notice served:	Enforcement
Details:	The Fire Safety Risk Assessment was not suitable and sufficient. Preventative and protective measures have not been implemented in accordance with the principles of prevention as specified in Part 3 of Schedule 1 of the Regulatory Reform (Fire Safety) Order 2005
Reference No	EN.NA.218
Date of compliance of notice:	12/06/2012

Date on which notice served:	03/04/2012
Name of Organisation:	The Cranberry Public House, 93 Dodworth Road, Barnsley S70 6HB
Type of notice served:	Enforcement
Details:	A Fire Safety Risk assessment has not been carried out.
Reference No	EN.NA.215
Date of compliance of notice:	02/05/2012

Date on which notice served:	20/03/2012
Name of Organisation:	Russell Eaton, 6 Shambles Street, Barnsley S70 2SW
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	EN.NA.210
Date of compliance of notice:	03/04/2012

Date on which notice served:	20/03/2012
Name of Organisation:	Clothiers Arms, 2 St Helens Street, Elsecar, Barnsley S74 8DE
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out. The structural fire precautions are inadequately maintained. The manual fire fighting equipment is inadequately maintained. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	EN.NA.209
Date of compliance of notice:	24/01/2013

Date on which notice served:	20/03/2012
Name of Organisation:	Heritage Music Studios, Building 11G, Elsecar heritage Centre, Wath Road, Elsecar, Barnsley S74 8HJ
Type of notice served:	Enforcement
Details:	To take such general fire precautions as will ensure the safety of persons who are not his employees. A Fire Safety Risk Assessment has not been carried out. The fire detection system is inadequate. The escape routes were not adequately lit.
Reference No	EN.NA.208
Date of compliance of notice:	20/07/2012

Date on which notice served:	13/03/2012
Name of Organisation:	The Sturdy Lads, Longridge Road, Monk bretton, Barnsley S71 2RZ
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment was not available at the time of the inspection. Fire exits and doors on escape routes could not be easily and immediately opened from the inside. The manual fire fighting equipment is inadequately maintained. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	EN.NA.206
Date of compliance of notice:	08/05/2012

Date on which notice served:	31/01/2012
Name of Organisation:	Galtee More Care Home, 164 Doncaster Road, Barnsley S70 1UD
Type of notice served:	Enforcement
Details:	The Fire Safety Risk Assessment was not suitable and sufficient. Preventative and protective measures have not been implemented in accordance with the principles of prevention as specified in Part 3 of Schedule 1 of the Regulatory Reform (Fire Safety) Order 2005.
Reference No	EN.NA.199
Date of compliance of notice:	10/07/2012

Date on which notice served:	27/01/2012
Name of Organisation:	Select Retail, Unit 10, The Alambra Shopping Centre, Cheapside, Barnsley S70 1SB
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out. The manual fire fighting equipment is inadequately maintained. The automatic fire fighting equipment is inadequately maintained. The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained. Inadequate co-operation with other responsible persons sharing the same premises to comply with the requirements and prohibitions imposed under the Regulatory Reform (Fire Safety) Order 2005.
Reference No	EN.NA.196
Date of compliance of notice:	31/08/2012

Date on which notice served:	24/01/2012
Name of Organisation:	The Green Dragon, Cote Lane, Thurgoland, Sheffield S35 7AE
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out.
Reference No	EN.NA.194
Date of compliance of notice:	07/03/2012

Date on which notice served:	20/12/2011
Name of Organisation:	Hoyland Catholic Social Club, West Street, Hoyland, Barnsley S74 9DL
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out. The fire alarm system is inadequately maintained. Inadequate safety training is provided to enable the employees to safeguard themselves and other persons on the premises.
Reference No	EN.NA.178
Date of compliance of notice:	12/03/2012

Date on which notice served:	01/12/2011
Name of Organisation:	Havenfield Lodge, Highfield Road, Darfield, Barnsley S73 9AY
Type of notice served:	Enforcement
Details:	A Fire Safety Risk Assessment has not been carried out. Preventative and protective measures have not been implemented in accordance with the principles of prevention as specified in Part 3 of Schedule 1 of the Regulatory Reform (Fire Safety) Order 2005.
Reference No	EN.NA.174
Date of compliance of notice:	01/05/2012

Date on which notice served:	01/09/2011
Name of Organisation:	Park Grange Care Home, Neville Avenue, Kendray, Barnsley, S70 3HF
Type of notice served:	Enforcement
Details:	The Fire Safety Risk Assessment was not suitable and sufficient. The existing fire evacuation strategy does not take into account the variation in shift patterns between day and night. It also does not address the arrangements for evacuation of those residents who may need to use a bedroom as a temporary refuge. The structural fire precautions are inadequately maintained.
Reference No	EN.NA.144
Date of compliance of notice:	28/08/2012

Date on which notice served:	22/06/2011
Name of Organisation:	Magicare Ltd, Willoughby House, St Johns Road, Cudworth, Barnsley, S72 8DE
Type of notice served:	Enforcement
Details:	The fire alarm system is inadequately maintained. The emergency lighting is inadequately maintained.
Reference No	EN.NA.134
Date of compliance of notice:	01/11/2011