

Doncaster District - Public Register of Notices Serviced – April 2021 to March 2023

The Enforcement Register – This register details Enforcement, Prohibition and Alteration Notices that have been served on business premises under the [Regulatory Reform \(Fire Safety\) Order 2005](#).

Date on which notice served:	02.12.2021
Name of Organisation:	Moorends Comrades Club and Institute, 160 Marshland Road, Moorends, Doncaster, DN8 4SB
Premises Type:	Licensed Premises
Type of notice served:	Enforcement
Details:	<p><b><u>Article 9 (1)</u></b> A Fire Safety Risk Assessment has not been carried out.</p> <p><b><u>Article 11 (1) &amp; (2)</u></b> Evidence that suitable fire safety arrangements are in place was not available at the time of the visit.</p> <p><b><u>Article 13 (1) (a) &amp; 13 (2)</u></b> The fire warning system is inadequate.</p> <p><b><u>Article 14 (2) (g)</u></b> The escape routes were not provided with adequate signage.</p> <p><b><u>Article 14 (2) (h)</u></b> The escape routes did not have adequate emergency lighting in case of failure of normal lighting circuits.</p> <p><b><u>Article 14 (2) (b)</u></b> The escape routes and exits could not be used as quickly and as safely as possible.</p> <p><b><u>Article 15 (1) (a)</u></b> Insufficient evacuation procedures and/or evacuation drills to be followed in the event of serious and imminent danger are in place.</p> <p><b><u>Article 17 (1)</u></b> The manual fire fighting equipment is inadequately maintained. The emergency lighting is inadequately maintained.</p> <p><b><u>Article 21 (2) (a)</u></b> Inadequate safety training is provided to enable the employees to safeguard themselves and other persons on the premises.</p>
Reference No:	EN.E.725
Date of compliance of notice:	

Date on which notice served:	14.10.2021
Name of Organisation:	Conisbrough Discounts, 69-71 Church Street, Conisbrough, Doncaster, DN12 3HP
Premises Type:	Ancillary Sleeping above Business Premises
Type of notice served:	Prohibition
Details:	Provide a protected means of escape route from the upper floors to a final exit or, provide an adequately fire separated alternative route to a final exit.  Provide a suitable means for detecting and warning in case of fire.
Reference No:	PN.E.716
Date of compliance of notice:	
Date on which notice served:	28.09.2021
Name of Organisation:	Dragon Heart, 210 Church Road, Stainforth, Doncaster, DN7 5NS
Premises Type:	Ancillary Sleeping above Business Premises
Type of notice served:	Prohibition
Details:	Prohibit relevant persons sleeping or resting on the first floor of the premises
Reference No:	PN.E.709
Date of compliance of notice:	<b>03.12.2021</b>