

Barnsley District - Public Register of Notices Served – April 2021 to March 2023

The Enforcement Register – This register details Enforcement, Prohibition and Alteration Notices that have been served on business premises under the [Regulatory Reform \(Fire Safety\) Order 2005](#).

Date on which notice served:	16.11.21
Name of Organisation:	Mayfair Chinese Take Away, 6-8 Hoyland Road, Hoyland, Barnsley, S74 0LY
Premises Type:	Ancillary Sleeping above Business Premises
Type of notice served:	Enforcement
Details:	<p>Article 9 (1) A Fire Safety Risk Assessment has not been carried out</p> <p>Article 13 (1) (a) & 13 (2) The system is inadequate fire detection</p> <p>Article 13 (1) (a) & 13 (2) The fire warning system is inadequate</p> <p>Article 13 (1) (a) & 13 (2) The fire fighting equipment is inadequate</p> <p>Article 14 (2) (a) The escape routes did not lead, as directly as possible, to a place of safety</p> <p>Article 14 (2) (b) The escape routes and exits could not be used as quickly and as safely as possible</p> <p>Article 14 (2) (h) The escape routes were not adequately lit</p>
Reference No:	EN.NA.722
Date of compliance of notice:	07.12.2021

Date on which notice served:	16.11.21
Name of Organisation:	Mayfair Chinese Take Away, 6-8 Hoyland Road, Hoyland, Barnsley, S74 0LY
Premises Type:	Ancillary Sleeping above Business Premises
Type of notice served:	Prohibition
Details:	<p>Insufficient means of escape</p> <p>Insufficient measures in relation to the means for detecting fire and giving warning in case of fire.</p>
Reference No:	PN.NA.723
Date of compliance of notice:	07.12.2021

Date on which notice served:	16.07.2021
Name of Organisation:	Skyline Apartments, Heelis Street, Barnsley, S70 1LB
Premises Type:	Purpose Built Flats
Type of notice served:	Prohibition
Details:	<p>Article 13</p> <p>Provide sufficient means for detecting fire and giving warning</p>
Reference No:	PN.NA.707
Date of compliance of notice:	26.08.2021

Date on which notice served:	22.07.2021
Name of Organisation:	Skyline Apartments, Heelis Street, Barnsley, S70 1LB
Premises Type:	Purpose Built Flats
Type of notice served:	Enforcement
Details:	Article 8 (1) (b)

	<p>To take such general fire precautions as will ensure the safety of persons who are not his employees</p> <p><u>Article 9 (1)</u></p> <p>The Fire Safety Risk Assessment was not suitable and sufficient</p>
Reference No:	EN.NA.708
Date of compliance of notice:	