

Barnsley District - Public Register of Notices Served – April 2021 to March 2023

The Enforcement Register – This register details Enforcement, Prohibition and Alteration Notices that have been served on business premises under the [Regulatory Reform \(Fire Safety\) Order 2005](#).

Date on which notice served:	07.03.2022
Name and Address of Premises:	Retrodome, Unit E, Upper New Street, Barnsley, S70 1LP.
Premises Type:	Amusement Arcade
Type of notice served:	Enforcement
Details:	<p><u>Article 9 (1)</u> A Fire Safety Risk Assessment has not been carried out.</p> <p><u>Article 13 (1) (a) & 13 (2)</u> The fire warning system is inadequate</p> <p><u>Article 14 (1)</u> The escape routes were obstructed</p> <p><u>Article 14 (2) (b)</u> The escape routes and exits could not be used as quickly and as safely as possible</p> <p><u>Article 14 (2) (h)</u> The escape routes did not have adequate emergency lighting in case of failure of normal lighting circuits</p> <p><u>Article 15 (1) (a)</u> Insufficient evacuation procedures and/or evacuation drills to be followed in the event of serious and imminent danger are in place</p> <p><u>Article 17 (1)</u> The structural fire precautions are inadequately maintained</p> <p><u>Article 17 (1)</u> The fire alarm system is inadequately maintained</p> <p><u>Article 17 (1)</u> The emergency lighting is inadequately maintained</p> <p><u>Article 21 (1) (a)</u> Inadequate safety training is provided to employees at the time when they are first employed</p> <p><u>Article 21 (2) (b)</u> Safety training to employees is not repeated periodically</p>
Reference No:	EN.NA.754
Date of compliance of notice:	11.05.2022

Date on which notice served:	17.02.2022
Name of Organisation:	United Fried Chicken, 299 Barnsley Road, Cudworth, Barnsley, S72 8SY
Premises Type:	Ancillary Sleeping above Business Premises
Type of notice served:	Prohibition
Details:	<p>The Fire and Rescue Authority are further of the opinion that the matter(s) which give rise to the said risk is:</p> <p>Inadequate means of escape.</p> <p>Inadequate means of protection to escape routes</p> <p>Inadequate detection and warning</p>
Reference No:	PN.NA.735
Date of compliance of notice:	

Date on which notice served:	16.11.21
Name of Organisation:	Mayfair Chinese Take Away, 6-8 Hoyland Road, Hoyland, Barnsley, S74 0LY
Premises Type:	Ancillary Sleeping above Business Premises
Type of notice served:	Enforcement
Details:	<p><u>Article 9 (1)</u> A Fire Safety Risk Assessment has not been carried out</p> <p><u>Article 13 (1) (a) & 13 (2)</u> The system is inadequate fire detection</p> <p><u>Article 13 (1) (a) & 13 (2)</u> The fire warning system is inadequate</p> <p><u>Article 13 (1) (a) & 13 (2)</u> The fire fighting equipment is inadequate</p> <p><u>Article 14 (2) (a)</u> The escape routes did not lead, as directly as possible, to a place of safety</p> <p><u>Article 14 (2) (b)</u> The escape routes and exits could not be used as quickly and as safely as possible</p> <p><u>Article 14 (2) (h)</u> The escape routes were not adequately lit</p>
Reference No:	EN.NA.722
Date of compliance of notice:	07.12.2021

Date on which notice served:	16.11.21
Name of Organisation:	Mayfair Chinese Take Away, 6-8 Hoyland Road, Hoyland, Barnsley, S74 0LY
Premises Type:	Ancillary Sleeping above Business Premises
Type of notice served:	Prohibition
Details:	<p>Insufficient means of escape</p> <p>Insufficient measures in relation to the means for detecting fire and giving warning in case of fire.</p>
Reference No:	PN.NA.723
Date of compliance of notice:	07.12.2021

Date on which notice served:	16.07.2021
Name of Organisation:	Skyline Apartments, Heelis Street, Barnsley, S70 1LB
Premises Type:	Purpose Built Flats
Type of notice served:	Prohibition
Details:	<p><u>Article 13</u></p> <p>Provide sufficient means for detecting fire and giving warning</p>
Reference No:	PN.NA.707
Date of compliance of notice:	26.08.2021

Date on which notice served:	22.07.2021
Name of Organisation:	Skyline Apartments, Heelis Street, Barnsley, S70 1LB
Premises Type:	Purpose Built Flats
Type of notice served:	Enforcement
Details:	<p><u>Article 8 (1) (b)</u></p> <p>To take such general fire precautions as will ensure the safety of persons who are not his employees</p> <p><u>Article 9 (1)</u></p> <p>The Fire Safety Risk Assessment was not suitable and sufficient</p>

Reference No:	EN.NA.708
Date of compliance of notice:	