

Doncaster District - Public Register of Notices Served – April 2025 to March 2027

The Enforcement Register – This register details Enforcement, Prohibition and Alteration Notices that have been served on business premises under the [Regulatory Reform \(Fire Safety\) Order 2005](#).

Date on which notice served:	29.05.2025
Name and Address of Premises:	Ashton Court Residential Home, 62 Blyth Road, Maltby, Rotherham S6 7LF
Premises Type:	Care Home
Type of notice served:	Enforcement
Details:	<p>Article 8 (1) (a) and Article 8 (1) (b) To take such general fire precautions as will ensure the safety of employees and persons who are not his employees</p> <p>Article 9 (1) The Fire Safety Risk Assessment was not suitable and sufficient</p> <p>Article 13 (1) (a) & 13 (2) The fire detection system is inadequate</p> <p>Article 14 (2) (b) The escape routes and exits could not be used as quickly and as safely as possible</p> <p>Article 14 (2) (h) The escape routes were not adequately lit</p> <p>Article 17 (1) The structural and passive fire precautions are inadequately maintained The emergency lighting is inadequately maintained</p>
Reference No:	EN/ND/1108 & EN/ND/1109
Date of compliance of notice:	

Date on which notice served:	30.05.2025
Name and Address of Premises:	China Garden, 143 Bentley Road, Bentley, Doncaster DN5 9TB
Premises Type:	Takeaway
Type of notice served:	Prohibition
Details:	<p>The Fire and Rescue Authority are further of the opinion that the matter(s) which give rise to the said risk is:</p> <p>A protected escape route must be established between the ground floor kitchen and the first-floor accommodation.</p>
Reference No:	PN/E/1112
Date of compliance of notice:	